

The PMCR Purchasing Group

[A Group comprised of delegated representatives of the Partnership of the Manitoba Capital Region to facilitate the tendering of specified goods.]

ADDENDUM

Addendum Number: 0005-2017 Addendum 1

Issued: February 23, 2017 by: Ken Sim

SUPPLY AND DELIVERY OF STRUCTURAL FIREFIGHTING HOSE

URGENT

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in **Form A: Bid Submission Paragraph 7** may render your Bid non-responsive.

PART A – BID SUBMISSION

- Acknowledge and list *0005-2017 Addendum 1*

The following is a summary of changes incorporated in the replacement Bid Submission:

Part – Section – Item	Changes
PART A – BID SUBMISSION FORM A: BID Paragraph 9	Revise: Form A: BID, paragraph 9 Contract Duration to read: The contract duration begins March 13, 2017 and ceases March 12, 2019 <u>subject to C3 Scope of Work C3.1.4.</u>
PART A – BID SUBMISSION FORM B: PRICES	Revise: Form B Prices to read: Subtitle; March 13, 2017 – March 12, 2019 Table; Supply contract duration March 13, 2017 – March 12, 2019
PART B – BIDDING PROCEDURES B2 SUBMISSION DEADLINE B2.1	Revise: B2.1 to read: The Submission Deadline is 4:00pm Winnipeg time, March 8, 2017.
PART C – GENERAL CONDITIONS C3 SCOPE OF WORK	Add: C3.1.4 to read: Due to potential revisions in the applicable NFPA standard, the contractor may make application to the Contract Administrator to adjust the unit price effective March 12, 2018. If a pricing adjustment is not agreed upon by both parties the Contractor may request to terminate the contract at no penalty.

Part – Section – Item	Changes
<p>PART C – GENERAL CONDITIONS</p> <p>C10 DELIVERY</p> <p>C10.1.1</p>	<p>Revise: C10.1.1 to read:</p> <p>Goods shall be delivered within <u>fifteen (15)</u> Business Day(s) of the placing of an order, unless otherwise agreed upon between Member and the Contractor at the time of ordering.</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.2</p>	<p>Revise D2.2 to read:</p> <p>The firefighting hose shall be compliant with NFPA 1961 (current edition) and ULC listed.</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.3 (b)</p>	<p>Revise D2.3 (b) to read:</p> <p>100% polyester jacket cover designed to increase abrasion resistance with 2 year warranty for wear;</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.3 (e)</p>	<p>Revise D2.3 (e) to read:</p> <p>Light weight, flexible to minus 50c, non-kinking;</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.3 (f)</p>	<p>Revise D2.3 (f) to read:</p> <p>Shall be available in NFPA colors. Color selection will be at time of order;</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.4 (b)</p>	<p>Revise D2.4 (b) to read:</p> <p>100% polyester jacket cover designed to increase abrasion resistance with 2 year warranty for wear;</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.4 (e)</p>	<p>Revise D2.4 (e) to read:</p> <p>Light weight, flexible to minus 50c, non-kinking;</p>
<p>PART D – SPECIFICATIONS</p> <p>D2 WORK</p> <p>D2.4 (f)</p>	<p>Revise D2.4 (f) to read:</p> <p>Shall be available in NFPA colors. Colour selection will be at time of order;</p>