

The PMCR Purchasing Group

[A Group comprised of delegated representatives of the Partnership of the Manitoba Capital Region to
facilitate the tendering of specified goods.]

ADDENDUM

Addendum Number: 0009-2017 Addendum 1

Issued: July 20, 2017 by: Ken Sim

**SUPPLY AND DELIVERY OF SPECIFIED FIRE DEPARTMENT SELF
CONTAINED BREATHING APPARATUS (SCBA), AIR CYLINDERS,
FACE PIECES AND OPTIONAL EQUIPMENT**

URGENT

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in **Form A: Bid Submission Paragraph 7** may render your Bid non-responsive.

PART A – BID SUBMISSION

- Acknowledge and list *0009-2017 Addendum 1*

The following is a summary of changes incorporated in the replacement Bid Submission:

Part – Section – Item	Changes
PART C – GENERAL CONDITIONS C15 WARRANTY	Revise: C15 WARRANTY to read: C15 WARRANTY AND SERVICE
PART C – GENERAL CONDITIONS C15 WARRANTY AND SERVICE	Add: C15.2 to read: To reduce inventory and compatibility challenges, only Scott X3 and MSA G1 products with rechargeable batteries (battery systems) are being considered in this bid opportunity.
PART D – SPECIFICATION D2 WORK D2.2	Revise: D2.2 to read: To reduce inventory and compatibility challenges, only Scott X3 and MSA G1 products with rechargeable batteries (battery systems) are being considered in this bid opportunity.
PART D – SPECIFICATION D4 VENDOR SPECIFICATION RESPONSE SUBMISSION D4.2 a)	Revise: D4.2 a) to read: Vendors must provide a list and prices of all rechargeable batteries required for basic SCBA operation and all electronic accessories.

Part – Section – Item	Changes
<p>PART D – SPECIFICATION</p> <p>D4 VENDOR SPECIFICATION RESPONSE SUBMISSION</p> <p>D4.2 u)</p>	<p>Revise: D4.2 u) to read:</p> <p>4500 PSI - 45 minute low profile carbon fiber wrapped cylinders are the standard cylinder to be used, with 60 minute versions as an option.</p>
<p>PART A – BID SUBMISSION</p> <p>FORM B: PRICES</p> <p>Item 1</p>	<p>Revise: Item 1 to read:</p> <p>Self Contained Breathing Apparatus complete with rechargeable batteries</p>
<p>PART A – BID SUBMISSION</p> <p>FORM B: PRICES</p>	<p>Add: Item 9 to read:</p> <p>9) 60 Minute Carbon Fibre air cylinder (each)</p>